



## Specifications of the sample which has sent from customer

Characteristics of Element							
Window (H: 1200 mm*W: 1500 mm) - Double - Tilt and turn right hand with one fixed light							
Specification	Components	Profile	Glass	Hardware and Fixing	Gasket	Reinforcement	Spacer
Material		UPVC	---	---	TPE	---	Aluminium
Type / Series		W640/Frame sash, Mullion, Double Glass Glazing bead (20 mm)	Double Glazed	Tilt and turn right hand	---	---	---
Producer			---	ACCADO		Pars Profil	---
Thickness		Class A	4-12-4	---	---	1.25 mm	12 mm
Producer Country		Iran	---	Turkey	Iran	Iran	---
Glue		---	---	---	---	---	---

## Result

Test Name	Classification									
Air permeability	1 <input type="checkbox"/>	2 <input type="checkbox"/>	3 <input checked="" type="checkbox"/>	4 <input type="checkbox"/>						
Water tightness	A1 <input type="checkbox"/>	A2 <input type="checkbox"/>	A3 <input type="checkbox"/>	A4 <input type="checkbox"/>	A5 <input type="checkbox"/>	A6 <input type="checkbox"/>	A7 <input type="checkbox"/>	A8 <input type="checkbox"/>	A9 <input checked="" type="checkbox"/>	
	B1 <input type="checkbox"/>	B2 <input type="checkbox"/>	B3 <input type="checkbox"/>	B4 <input type="checkbox"/>	B5 <input type="checkbox"/>	B6 <input type="checkbox"/>	B7 <input type="checkbox"/>			
Resistance to wind load	A1 <input type="checkbox"/>	A2 <input type="checkbox"/>	A3 <input type="checkbox"/>	A4 <input type="checkbox"/>	A5 <input type="checkbox"/>					
	B1 <input type="checkbox"/>	B2 <input type="checkbox"/>	B3 <input type="checkbox"/>	B4 <input type="checkbox"/>	B5 <input type="checkbox"/>					
	C1 <input type="checkbox"/>	C2 <input type="checkbox"/>	C3 <input type="checkbox"/>	C4 <input type="checkbox"/>	C5 <input checked="" type="checkbox"/>					
Repeated Pressure Test	OK <input checked="" type="checkbox"/>	NOT OK <input type="checkbox"/>								
Safety Test	OK <input checked="" type="checkbox"/>	NOT OK <input type="checkbox"/>								

\* بر اساس استاندارد های رده بندی، برای هر آزمون، رنگ های سیرتر جدول، بیانگر کلاس بالاتر و کیفیت بالای آزمون می باشد.

### NOTE :

This certificate has been merely issued in accordance with tests which have been conducted in Adopen Plastic Persian Reference Laboratory for the sample which has been recieved with above described features and it is not valid for all of the products of the applied manufacturer.

آزمایشگاه تایید صلاحیت شده  
آزمون Testing  
NACI/LAB/624