

# CERTIFICATE

**Customer:** **BEHINE GOSTAR NAMAYE AFTAB COMPANY (.Pvt)**

Avand Building - Unit 4 - No 182 - Beginning of Jalal-e-Ahmad Highway - Ashrafi Esfahani Exp way  
Tehran

**Sample:** **Window (H: 1200 mm\*W: 1500 mm) - Double - Tilt and Turn Right Hand with one Fixed Light - Accessory Brand: ACCADO**

**Type of used Profiles:** **WINTeCH** Series: **W 640 - Cross Section: 60 mm - 4 chamber**

**Technical certificates of used profiles :** holds "Grade A" certificates from German "RAL" institute and Iranian standard national organization, and "Road, Housing and Urban development Research center(bhrc)".

**Scope:**

Dedicated to  
window and door

- Air permeability- test and classification according to BS EN 1026, DIN EN 12207, ISIRI 7822, INSO 11093
- Water tightness- test and classification according to BS EN 1027, DIN EN 12208, ISIRI 11864, ISIRI 7821
- Resistance to wind load- test and classification according to BS EN 12211 BS EN 12210, INSO 11421, INSO 11420

**Issuer:** **Specialized and Technical Laboratory of ADOPEN PLASTIC PERSIAN**, holds certificate of **ISO/IEC17025** from National Accreditation Center of Iran (NACI).

**Issue Date:** **27-06-2020**

**Certificate Registration No. :** **990402115901**

**Test Result:** With this regard, **Adopen Plastic Persian laboratory**, certified and approved that, the window Sample as described above, based on the relevant standards and using a door and window insulation measurement device (Manufactured by German **KS** Company) against atmospheric conditions has been tested and the following classes have been achieved:

**Air permeability Class 3 ,Water tightness Class A9,Resistance to wind load Class C5**

**Report:**

According to the obtained results, The tested upvc window is accordance with the standard requirements for Air permeability, Water tightness, Resistance to wind load and safety tests and approved for using in building projects .

*Kaveh Khodaparast*

Kaveh Khodaparast  
CEO and Chairman of  
Adopen Plastic Persian Test Laboratory

**NOTE :**

This certificate has been merely issued in accordance with tests which have been conducted in Adopen Plastic Persian Reference Laboratory for the sample which has been recieved with above described features and it is not valid for all of the products of the applied manufacturer.

The responsibility of any exploit, Other than the cases stipulated in the certificate, is in charge of applicant.

This certificate issued in 3 pages with serial No. 990402115901 and attached test report in 21 pages